



1. ALL MATERIAL AND EQUIPMENT TO BE NEW AND UL LISTED OR FM APPROVED.
2. PIPE HANGERS AND METHOD OF HANGING TO BE IN ACCORDANCE WITH NFPA PAMPHLET #13.
3. PIPING SHALL BE IN ACCORDANCE WITH NFPA PAMPHLET #13.
4. JOINING OF PIPE AND FITTINGS, THREADED AND WELDED SHALL BE IN ACCORDANCE WITH NFPA PAMPHLET #13.
5. OWNER TO PROVIDE ADEQUATE HEAT TO PREVENT WATER IN PIPES FROM FREEZING IN AREAS PROTECTED BY A WET PIPE SPRINKLER SYSTEM.
6. STRUCTURAL ADEQUACY OF THE BUILDING TO SUPPORT THE SPRINKLER PIPING IS THE RESPONSIBILITY OF THE OWNER AND/OR HIS STRUCTURAL ENGINEER.
7. ALL FIRE ALARMS, WIRING AND MONITORING ARE TO BE INSTALLED BY OTHERS.

1. ALL NEW HEADS ARE LIGHT HAZARD MAX SPACING IS 225 SQ.FT. PER NFPA 13.
2. PIPING SIZED PER EXISTING PIPE SCHEDULE.
3. ARMOVERS OVER 24" TO HAVE A HANGER.



-
- VIEW DR.
- CARILLON PT.
- 4100
- N
- SITE MAP

PARCEL # - XXX
PERMIT # - XXX

